

Multilevel Inverter Connected To PV System with MPPT

HIMANSHU SHUKLA¹, ASHISH PATRA², KULDEEP SWARNKAR³

¹ Student, Madhav institute of technology and science Gwalior (m.p.)

^{2,3} Associate Professor, Madhav institute of technology and science, Gwalior (m.p.)

Abstract- *An improved MPPT converter with voltage and current (perturb & observe) method for photo voltaic (PV) and 5-level H-bridge multilevel inverter is connected to solar panel, applications is presented in this paper. The proposed method used to implements maximum power point tracking (MPPT) and convert DC power into AC power by variable reference of voltage and current which is continuously changed during some time (up to 5 sec). In this algorithm a slight perturbation is introduce system. Due to this perturbation the power of the module changes. If the power increases due to the perturbation then the perturbation is continued in that direction. After the peak power is reached the power at the next instant decreases and hence after that the perturbation reverses. When the steady state is reached the algorithm oscillates around the peak point. In order to keep the power variation small the perturbation size is kept very small. The algorithm is developed in such a manner that it sets a reference voltage of the module corresponding to the peak voltage of the module. It is also observed that this algorithm fails to track the power under fast varying atmospheric conditions.*

I. INTRODUCTION

Renewable energy sources play an important role in electricity generation. Various renewable energy sources like wind, solar, geothermal, ocean thermal, and biomass can be used for generation of electricity and for meeting our daily energy needs. The power generated by a Photo Voltaic (PV) Module depends on the operating voltage and current of the photovoltaic cell and its voltage-current and voltage-power characteristic curves specify a unique operating point at which maximum possible power is delivered and the PV module is operated at its highest efficiency. One of the problems in designing efficient PV systems is to track the maximum power operating point for varying solar irradiance levels and ambient conditions. The photovoltaic generator exhibits nonlinear V-I

characteristics and maximum power point varies with solar insolation. A dc-dc converter is used to match the PV system to the load and to operate solar array at maximum power point and an Inverter is used to connect the AC system. The cascaded H-bridge is a suitable topology for connecting multiple panels in series and sinusoidal PWM is employed to generate a sinusoidal terminal voltage and to control its magnitude so that it can be interfaced with the AC system.

A new MPPT algorithm based on the fact that the MPOP (maximum peak operating point) of a PV generator can be tracked accurately by comparing the incremental and instantaneous conductance of the PV array. The work was carried out by both simulation and experiment, with results showing that the developed incremental conductance (IntCond) algorithm has successfully tracked the MPOP, even in cases of rapidly changing atmospheric conditions, and has higher efficiency than ordinary algorithms in terms of total PV energy transferred to the load [1].

A robust oscillation method is used for implementing the maximum power point tracking for the solar arrays. The method uses only one variable that is load current for detecting the maximum power. This method is suitable for the battery charging application where MPPT is to be implemented. The algorithm is implemented through a simple circuit. The paper gives detailed discussion about design of a step up converter. Used for the MPPT [2].

A new kind of maximum power point tracking algorithm based on perturb and observe algorithm. The algorithm is fast acting and eliminates the need of a large capacitor which is normally used in perturb and observe algorithm to eliminate the ripple in the module voltage. The module voltage and current that are taken for processing are not averaged but are instantaneous this speed ups the process of peak power tracking [3].

This improved MPPT algorithm based on perturb and observe. The algorithm uses the power as the control variable based on the perturbation and observation method. The algorithm requires two sensors. A better response for the system under rapid atmospheric condition variations is obtained by increasing the execution speed [4].

II. MATLAB MODEL OF THE PV MODULE

The simulation of solar PV module characteristics, perturb & observe (P & O) algorithm of Maximum power point tracking (MPPT), PV model along with MPP tracking is done on the MatLab/Simulink.

IV and PV characteristics of Solar PV model is shown in the figure 5&6

- Open circuit voltage (V_{oc}) = 22.22V
- Short circuit current (I_{sc}) = 5.45 A
- Current at Pmax = 4.95A
- Voltage at Pmax=17.2 V
- Diode "ideality factor" $m=2$
- Thermal Voltage = $v_T = (k.T/e)$
- Constant of Boltzmann $k= 1.380658 \times 10^{-23} \text{ Jk}^{-1}$
- Charge of an electron $e=1.6021733 \times 10^{-19}$ as
- Insolation= $800W / M^2$

The MATLAB code computes model parameters I_o , R_s , R_p based on the model parameters (short-circuit current I_{sc} , circuit voltage V_{oc} , rated voltage V_r , and rated current I_r).




Fig1. P-V Characteristics of PV Module




Fig2. I-V Characteristics of PV Module

III. CHARACTERISTICS OF SOLAR PV MODULE AT DIFFERENT INSOLATION

Insolation = 200, 400, 600, 800, 1000 W / M^2




Fig3. I-V Characteristics of PV Module at different Insolation




Fig4. P-V Characteristics of PV module at different insolation

IV. ALGORITHM TO TRACK THE MAXIMUM POWER POINT

- Perturb and observe:
In this algorithm a slight perturbation is introduced into the system. Due to this perturbation the power of the module changes. If the power increases due to the perturbation then the perturbation is continued in that




Fig11. Current Vs time

Fig9 is power vs time. Initially power drawn from solar panel is less. Then duty ratio is increased via algorithm. Fig12 is voltage versus time. Initial condition is more towards open circuit condition due to which voltage is high. As duty ratio increases current drawn (Fig11) from solar panel increases which result in drop in voltage. Finally, when the power is reach to the maximum point duty ratio is set and power is oscillate around the maximum power. Here maximum power is 82watt




Fig12. Duty ratio Vs time




Fig.13 switching pulse for the switch of the buck chopper

Fig12 shows the pulses which is generated by the perturb and observe algorithm of maximum peak power point ,this pulses is used for the drive the

switch(MOSFET) of the DC Buck converter for extracting the maximum power from solar photovoltaic module.

CONCLUSION

Power output of PV module improves with the MPPT system. It is observed that the module gives the peak output power up to 82 watt. The temperature has effect on the peak power. From the plots fig 3 and 4 it was observed that as the insolation increases the peak increase.

REFERENCES

- [1] K. H. Hussein *et al*, “Maximum Photovoltaic Power Tracking: An Algorithm for rapidly changing atmospheric conditions,” *Proc. Inst. Elect. Eng.* vol. 142, pt. G, no. 1, pp. 59–64, Jan. 1995
- [2] C.R. Sullivan and M.J. Powers,” A High-Efficiency Maximum Power Point Tracking for Photovoltaic Arrays in a Solar-Power Race Vehicle”, IEEE PESC’93, 1993, pp.574-580.
- [3] Xuejun Liu and A.C.Lopes, “An Improved Perturbation and Observe Maximum Power Point Tracking Algorithm for PV Arrays” IEEE PESC ‘2004, pp.2005-2010.
- [4] Chihchiang Hua, Jongrong Lin, and Chihming Shen,“Implementation of a DSP Controlled Photovoltaic System with Peak Power Tracking”, IEEE transactions on industrial electronics, vol. 45, no. 1, february 1998 pp 99-107.
- [5] B.K. Bose, P.M. Szczesny and R.L. Steigerwald,“Microcomputer Control of a Residential Photovoltaic Power Conditioning System”, IEEE Trans. on Industry Applications, vol. IA-21, no. 5,Sep. 1985, ppl182-1191.
- [6] Xuejun Liu and A.C.Lopes, “An Improved Perturbation and Observe Maximum Power Point Tracking Algorithm for PV Arrays” IEEE PESC ‘2004, pp.2005-2010.
- [7] D. P. Hohm, M. E. Ropp, “Comparative Study of Maximum Power Point Tracking Algorithms Using an Experimental, Programmable, Maximum Power Point Tracking Test Bed”,IEEE,2000.pp.1699-1702.